

Certificate No:

SGS/090398

CERTIFICATE OF COMPLIANCE

This certificate is issued to confirm that **SGS Systems & Services Certification Pty Ltd** (Electrical Product Certification Services (EPCS) Australia) has certified the equipment / appliance / accessory described hereunder to comply with the minimum safety standards for which the Application has been made by:-

SELECTRONIC AUSTRALIA PTY LTD Suite 5, 20 Fletcher Road CHIRNSIDE PARK VIC 3116 AUSTRALIA

DESCRIPTION OF ELECTRICAL EQUIPMENT

Class:

Inverter Energy Sytem

Product:

Grid Connected Solar / Battery Inverter

Trade Name / Manufacturer:

SP PRO

Catalogue / Model No(s):

SPMC241-AU; SPMC481-AU and SPMC482-AU

Manufacturer:

Same as applicant

Ratings:

Refer to certificate addendum for details

Standard No.:

AS 4777.2:2005 AS 4777.3:2005 AS 62040 1 1:2003

MARKING:

SGSE/090398

EXPIRY DATE:

28 July 2014

DATE OF CERTIFICATION:

29 July 2009

For and On Behalf of

SGS Systems & Services Certification Pty Ltd



SGSSGSGSGSGSGS



Certificate No:

SGS/090398

Certificate Addendum

(Page 1 of 1)

Ratings:

SPMC241-AU:

Input: 210-240 V a.c.; 63 A; Class I Inverter Output: 240 V a.c.; 50 Hz; 3.5 kW (3.5 kVA; PF 0.1-1.0) d.c. Input voltage: 24 V (20-34 V) 3.5 kW Battery charge current: 145 A IP43

SPMC481-AU:

Input: 210-240 V a.c.; 63 A; Class I Inverter Output: 240 V a.c.; 50 Hz; 4 kW (4 kVA; PF 0.1-1.0) d.c. Input voltage: 48 V (40-68 V) 4 kW Battery charge current: 83 A IP43

SPMC482-AU:

Input: 210-240 V a.c.; 63 A; Class I Inverter Output: 240 V a.c.; 50 Hz; 6 kW (6 kVA; PF 0.1-1.0) d.c. Input voltage: 48 V (40-68 V) 6 kW Battery charge current: 125 A IP43

For and On Behalf of SGS Systems & Services Certification Pty Ltd