

Certificate No: SGS/090398/1

CERTIFICATE OF COMPLIANCE

Modification Addendum

This certificate is issued as a modification addendum to Certificate No.: SGS/090398 to confirm that **SGS Systems & Services Certification Pty Ltd** (Electrical Product Certification Services (EPCS) Australia) has certified the modification described hereunder to comply with the minimum safety standards for which the application for modification has been made by :-

SELECTRONIC AUSTRALIA PTY LTD
 Suite 5, 20 Fletcher Road
 CHIRNSIDE PARK VIC 3116
 AUSTRALIA

DESCRIPTION OF MODIFICATION

Class:	Inverter Energy System
Product:	Grid Connected Solar / Battery Inverter
Trade Name / Manufacturer:	SP PRO
Catalogue / Model No(s):	Addition of: SPMC240-AU
Manufacturer:	Same as applicant
Ratings:	Input: 210-240 V a.c.; 63 A; Class I Inverter output: 240 V a.c.; 50 Hz; 2.5 kW (2.5 kVA; PF 0.1-1.0) d.c. Input: 24 V (20-34 V) 2.5 kW Battery charge current: 105 A IP43
Standard No.:	AS 4777.2:2005 AS 4777.3:2005 AS 62040.1.1:2003

MARKING:	SGSE/090398
EXPIRY DATE:	28 July 2014
DATE OF CERTIFICATION:	29 July 2009
DATE OF MODIFICATION:	20 November 2009



For and On Behalf of
SGS Systems & Services Certification Pty Ltd

